

Base

Contractor responsible


to cover any exposed

approved edge detail

by a minimum of 1 inch

wood nailers with

metal flashing or



Note 1: This detail may also be used on parapet walls.

Approved cover

insulation (Note 7)

Approved vapor

barrier (Note 7)

board (Note 7)

Approved

Note 2: The use of this detail is not to exceed a 2-inch per 12-inch slope.

Deck

Wood nailer

(Note 6)

- Note 3: Allow for 1/8-inch expansion gap between 10-foot lengths of snap-on base. Overlap snap-on covers by 2 inches between 10-foot lengths.
- Note 4: When installing this detail with a 6-inch or greater vertical surface, an additional fastening row must be located approximately 1 1/8 inches from bottom of snap-on base.

Note 4

- Note 5: All field welds shall be a minimum of 1-1/2 inches wide.
- Note 6: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. The installing contractor is responsible for meeting building codes.
- Note 7: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED:	08/17/2017	EDGE DETAIL FOR ADHERED DURO-FLEECE SYSTEMS
PREVIOUS:	01/01/2009	UNIVERSAL 2-PIECE COMPRESSION EDGE
SCALE:	NONE	NEW CONSTRUCTION OR RE-ROOF