



- Note 1: This detail cannot be used on drains larger than 2 inches in diameter.
- Note 2: The membrane shall be terminated through the drain pipe flange and directly to the deck as shown above. The membrane cannot be terminated through insulation, existing roofs or recover boards.
- Note 3: All field welds shall be a minimum of 1-1/2 inches wide.
- Note 4: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: 02/01/2017	DRAINAGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 01/01/2009	2-INCH DRAIN ADAPTER
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF