



Note 1: Overlap each 10-foot length of base by 1-inch. Overlap the covers by 1-1/2 inches utilizing the pre-notched end on 10-foot lengths.

Note 2: Wood nailers must withstand a minimum force of 180 pounds per lineal foot (per building code). Any pull values greater than 270 pounds will allow for a fastener spacing of 18 inches on center. Pull values less than 270 pounds will require additional fasteners. **The installing contractor is responsible for meeting building codes.**

Note 3: Refer to specifications for vapor barrier, insulation, and cover board requirements

REVISED: 06/04/2018	EDGE DETAIL FOR MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 05/10/2017	ALL-TERM™
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF