



Note 1: Tabs that are parallel to the expansion joint must be mechanically fastened with the same fastening pattern used on the membrane in the field area.

Note 2: All field welds shall be a minimum of 1-1/2 inches wide.

Note 3: Refer to specifications for vapor barrier, insulation and cover board requirements.

REVISED: 03/03/2017

GENERAL DETAIL FOR MECHANICALLY FASTENED SYSTEMS

PREVIOUS: 01/31/2017

DECK-TO-WALL EXPANSION JOINT

SCALE: NONE

NEW CONSTRUCTION OR RE-ROOF