



Note 1: The minimum slope requirement for this detail is 1 inch per 12 inches.

Note 2: All field welds shall be a minimum of 1-1/2 inches wide.

Note 3: Refer to Detail Drawings 8000 and 8005 for insulation, cover board and hard board installation requirements.

REVISED: 03/17/2017	METAL ROOF RECOVER
PREVIOUS: 01/01/2009	METAL ROOF TIE-IN
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF