



Note 1: This detail applies to all 50 mil or greater roll good membrane installations (excluding Shingle-Ply®). A patch is required at all lap areas where 3 or more layers of membrane intersect (T-Lap) as illustrated above. If 1 of the 3 layers is 40-mil, a patch is not required.

Note 2: Patches can be made of either DT or DL membrane of any thickness. DL EV patches shall only be used on DL EV membranes.

Note 3: Minimum patch size is 4x4 inches if rectangular and 4 inches in diameter if circular.

Note 4: All field welds shall be a minimum of 1-1/2 inches wide.

Note 5: Refer to RG1064 for fastener placement and sheet overlap.

REVISED: 02/03/2017	GENERAL DETAIL FOR ROLL GOOD MECHANICALLY FASTENED SYSTEMS
PREVIOUS: 08/01/2012	LOCATION OF T-LAP PATCHES
SCALE: NONE	NEW CONSTRUCTION OR RE-ROOF