

# NOTIFICATION OF ENERGY STAR® PRODUCT CERTIFICATION

Partner's EPA-issued Organization ID #: 28148

**Partner Name:** Duro-Last Roofing Inc.  
**Product Brand Name:** Duro-Last membrane  
**Product Model Name:** Duro-Last 1004 XW

CB Unique Model Identifier: ES-DUR-0004  
ENERGY STAR Specification Version: 3.0  
Initial Solar Reflectance: 0.88  
Solar Reflectance After 3 Years: 0.68  
Initial Emissivity: 0.87  
Slope Category: Low Slope? Yes Steep Slope? Yes

The Cool Roof Rating Council (CRRC), an ISO/IEC 17065 accredited EPA Certification Body, has reviewed the test results data provided by an EPA-certified testing laboratory and has determined that this roofing product meets the qualification criteria of ENERGY STAR's Program Requirements Product Specification for Roof Products.

This Notification of Product Certification is subject to all terms and conditions of the ENERGY STAR Partnership Agreement, ENERGY STAR Program Requirements for Roof Products: Partner Commitments and Eligibility (in accordance with the version that product is certified under), Evaluation Services-CRRC Agreement, and the Evaluation Services Certification Program Manual.

This Notice of Product Certification is only valid based on the certification status of the product. To determine if the product is actively certified please visit ENERGY STAR's Qualified Product List at:

<http://www.energystar.gov/productfinder/product/certified-roof-products/results>



Application Review



Management Approval

2017-03-21

Date

Certificate provided by:  
**Cool Roof Rating Council**  
449 15th St. Suite 400  
Oakland, CA 94612

Certificate provided to:  
**Duro-Last Roofing Inc.**  
525 Morley Drive  
Saginaw, MI, 48601